

Seneca County Department of Health
Environmental Services
2465 Bonadent Drive, Suite 3 , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Mobile Home Park Inspection -- Summary Report

Operation: FINGER LAKES MOBILE HOME PARK (ID: 308090)
Facility Name: FINGER LAKES MOBILE HOME PARK
Facility Code: 4900686 Facility Email: linda@victor-corporation.com
Facility Address: 3917 96A ROUTE GENEVA, NY 14456

To the Attention of:
VICTOR MOBILE HOME PARKS, INC. LINDA HANNAN
784 OLD DUTCH ROAD
VICTOR , NY 14564- Owner/Operator Email: linda@victor-corporation.com

Inspection

Date: APR 10, 2019 01:56 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Bob King
(email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 1

Each item found in violation is reported below along with the code requirement.

SEWAGE

ITEM # 24 WAS FOUND IN VIOLATION 1 TIME(s).

All or parts of the violation item are IN violation.

Code Requirements

Sewage system construction & maintenance {17.6 (b)(1),(2)}

Inspector Findings

Septic tank servicing lot c, d and e has sewage surfacing from leach field. Septic system must be serviced and repaired.

Additional Information Collected During Inspection

Comments

Skirting on lot q, h and r needs to be repaired/replaced. Chlorine found at 1.13 in pump house. Chlorine found at lot P was .66 within the distribution system.

END of REPORT

[Submit# 503293] FINGER LAKES MOBILE HOME PARK (ID 308090) Inspection#

1002430163