

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Swimming Pool Inspection -- Summary Report

Operation: Babcock Hovey - Outdoor Pool (ID: 308214)
Facility Name: BABCOCK-HOVEY BSA
Facility Code: 49-0019 Facility Email: don.declerck@scouting.org
Facility Address: 7294 COUNTY ROAD 132 ROAD OVID, NY 14521

To the Attention of:
STEVE HOITT SENECA WATERWAYS COUNCIL, BSA
2320 BRIGHTON HENRIETTA TOWNLINE RD
ROCHESTER , NY 14623- Owner/Operator Email: don.declerck@scouting.org

Inspection

Date: AUG 01, 2017 04:59 PM
Inspector: Julie Hoster (jhoster@co.seneca.ny.us)
Responsible Person: Howard Barnes
(email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 1

Each item found in violation is reported below along with the code requirement.

GENERAL

ITEM # 50 WAS FOUND IN VIOLATION 1 TIME(s).

All or parts of the violation item are IN violation.

Code Requirements

Bathhouse/Toilet Facilities Adequate, Clean, Ventilated, Warm Water, Soap, Hand Drying Facilities Provided, Refuse Storage, Disposal {6-1.14, 6-1.15}

Inspector Findings

bath house has cobwebs and unclean; no soap in showers

Additional Information Collected During Inspection

Free chlorine/bromine - 1.5 mg/L; pH - 7.4; Total alkalinity - 90 mg/L; Calcium hardness - 120 mg/L; Temporary Residence/Campground - No; Homeowner exemption - No;

Comments

END of REPORT

[Submit# 312148] Babcock Hovey - Outdoor Pool (ID 308214) Inspection# 1002153428